



N00296.000532  
MOFFETT FIELD  
SSIC NO. 5090.3

Industrial Pretreatment Program

Telephone (408) 730-7273

November 30, 1988

J. G. Sims  
CDR, CEC, USN  
Public Works Officer  
Naval Air Station  
Building 566  
Moffett Field, CA 94035

Dear Cdr. Sims:

THIS LETTER SUPERSEDES THE APPROVAL LETTER PREVIOUSLY SENT ON  
AUGUST 19, 1988

I have reviewed your request to discharge groundwater and wastewater from the decontamination of equipment to the sanitary sewer from installation and development of 109 monitoring wells at Naval Air Station, Moffett Field. It has been our policy to accept the type of discharge in an effort to facilitate groundwater cleanup activities. These requests are reviewed under a general policy guideline and considered on a case by case basis.

Your request as outlined in your July 8, 1988 letter is within the allowable parameters of our general policy. We will accept this discharge under the following conditions:

1. This approval is valid from July 15, 1988 to July 15, 1989.
2. Each batch of groundwater or decontamination wastewater must be sampled using appropriate, properly prepared sample bottles and proper sampling techniques. The samples must be analyzed using EPA Method 601/602 and analytical procedures from Standard Methods for the Examination of Water and Wastewater for pH, cadmium, chromium, copper, lead, nickel, and zinc.
3. The analysis of each batch must be provided to us in writing and verbal approval given by us prior to the discharge of any wastewater.
4. A detailed log must be maintained showing the sample date, sample time, discharge date, discharge time, and total gallonage discharged for each batch. Copies of this log must be submitted on October 31, 1988, January 31, 1989, April 30, 1989, and July 31, 1989.
5. You have been granted a variance from Sunnyvale Municipal Code Section 12.12.100 and may discharge groundwater into the sanitary manholes designated #2, #8, #37, and the manhole at the northeast corner of Building 146. This variance applies to approved groundwater discharged only.
6. The flow rate must be controlled to prevent hydraulic overloading of the sewer lines in the area.
7. This approval is valid only for those operations described in your July 8, 1988 letter, and is not valid for wastewater from any industrial process. Groundwater

ADDRESS ALL MAIL TO: P.O. BOX 3707 SUNNYVALE, CALIFORNIA 94086-3707  
For deaf access, call TDD/TTY (408) 730-7501

532

GEN 19

J. G. Sims  
November 30, 1988  
Page 2


from other activities, such as but not limited to pump test or cleanup activities, must be approved separately.

8. There is an annual fee of \$238.94 for each approved program of up to 100,000 gallons annually, payable in advance. You will receive an invoice from the City of Sunnyvale Revenue Department.

This approval may be withdrawn if it is found to have been obtained through false information or if there is an unapproved deviation from the terms and conditions under which it has been granted.

If you have any questions, you may call me at the above number.

Sincerely,



Christopher L. de Groot  
Industrial Waste Inspector

pjm